



NOTES:

- 1. ALL METERS SHALL BE INSTALLED WITHIN CITY OF SAVANNAH RIGHT OF WAY OR EASEMENT.
- CONCRETE COLLAR IS NOT REQUIRED ON VALVE BOXES INSTALLED IN PAVED AREAS.
- 3. A 2" PIPE MAY BE USED FOR UP TO SIX
 (6) UNITS. 2" PIPE SHALL BE POLYETHYLENE.
- 4. AN APPROVED BACKFLOW PREVENTOR MUST BE INSTALLED APPROPRIATE FOR THE BUILDING USE IN ACCORDANCE WITH THE CITY'S STANDARDS. THE USE OF A SINGLE BACKFLOW PREVENTOR UPSTREAM OF THE METER MANIFOLD MAY BE ALLOWED, IF APPROVED BY THE CITY FOR THE PROPOSED USE.

MANIFOLD FOR MULTIPLE METERS INST.

STANDARD CONSTRUCTION DETAILS



SCALE: N.T.S.

DATED: SEP 2013

PLATE NUMBER:

W7